

**ADDENDUM # 1**  
**IFB 19-07-325 CCTV Camera Replacement**

August 26th, 2019

To: All Vendors of Record

RE: Addendum #1

**All vendors are to accept the information contained herein as the official response of IPTC.**

**TO ALL BIDDERS OF RECORD AND TO WHOM IT MAY CONCERN:**

This Addendum is being issued prior to the due date for receiving quotes.

This Addendum forms a part of the Contract Documents and modifies the original IFB as noted below and shall be incorporated into the Contract Documents. All other provisions of this IFB released August 12, 2019, with the exception of changes below, shall remain unchanged.

This Addendum is issued in accordance with the provisions of the IFB document. All Quotes shall be based upon work as modified by this Addendum.

Acknowledged receipt of this Addendum on the Acknowledgement of Addendum Form is required. Failure to do so may result in disqualification of the Bidder.

This addendum addresses SSI Document IndyGo CCTV Record Drawings with SSI  
Page 2.

## GENERAL NOTES:

- 1) CONSULT SIMPLEXGRINNELL PRIOR TO MAKING MODIFICATIONS TO SYSTEM WIRING.
- 2) CCTV WIRING SHALL BE RUN SEPARATE FROM ALL ANOTHER SYSTEM WIRING.
- 3) ALL SYSTEM WIRING MUST BE TESTED AND FREE OF OPENS, SHORTS, AND GROUNDS.
- 4) CONDUIT AND JUNCTION/BACK BOXES ARE NOT TO BE USED FOR UNRELATED WIRING.
- 5) INSTALLATION METHODS AND MATERIALS SHALL CONFORM WITH ALL APPLICABLE SECTIONS OF THE ELECTRICAL CODE.
- 6) THESE DRAWINGS ARE DIAGRAMMATIC. THEY SHOW DEVICE LOCATION, NUMBER OF CONDUCTORS, WIRE TYPE, CIRCUITING AND ROUTING. IT IS THE RESPONSIBILITY OF THE ELECTRICAL CONTRACTOR TO ENSURE THAT ALL CONDUIT AND PULL BOXES ARE SIZED IN ACCORDANCE WITH THE FULL REQUIREMENTS OF THE ELECTRICAL CODE.

***IPTC Response: Bidders must develop bids based on the work shown on the set of drawings marked "Bid Set", dated 08/09/19. The set of drawings marked "Record Drawings", dated 09/23/09 do not contain any new work. The "Record Drawings" show the existing CCTV system layout as it was installed in 2009. IndyGo's intent on providing the "Record Drawings" was to provide the bidders with an overall understanding of the layout of the existing CCTV system as an aid with the development of bids.***

**ACKNOWLEDGMENT OF ADDENDUM**

(Must be returned with your Offer)

**IFB 19-07-325 CCTV Camera Replacement**

The undersigned acknowledges receipt of the following amendment(s) to the Bid and supporting documentation.

ADDENDUM NUMBER \_\_\_\_\_ DATED: \_\_\_\_\_

Note: Failure to acknowledge receipt of all addendums that may have been issued may cause the Proposal offer to be considered non-responsive to the solicitation. No further consideration will be given to non-responsive offers. Acknowledged receipt of each addendum must be clearly established and included with the bid response.

(Proposing Company Name)

(Street Address)

(City, State, and Zip Code)

\_\_\_\_\_  
Signature of Authorized Company Official

\_\_\_\_\_  
Date